

ha

RESULTS OF EXAMINATION OF WATER

LABORATORY NO. B 12144		COLLECTED BY J. Guzewich	
DATE COLLECTED 9/12/72		RECEIVED 9/12/72	REPORTED 9/14/72
CITY, VILLAGE, TOWN &/ OR NAME OF SUPPLY Thompson Dock			COUNTY Warren
OWNER Dr. Lake Champlain Subwatershed Eagle Lake			TENANT
SAMPLING POINT Thompson Dock			
BACTERIA PER ML (Agar plate count at 35° C.)		COLIFORM GROUP (Membrane Filter Cols-/100 ml.) 800	RESIDUAL CHLORINE AS RECORDED AT
			SAMPLING POINT
			POINT OF TREATMENT
CHLORIDES (Cl)-mg./l.	NITRATES (as N)-mg./l.	<del>COLIFORM GROUP (Membrane Filter Cols-/100 ml.)</del> Fecal coli <10	

These results indicate that the water was of a satisfactory sanitary quality when the sample was collected.

Sanitary Engineer